

| <i>* all units in m³/day</i> | | | | | | | |
|---|-------------------------|-------------------------|--------------------------------|--|--|--|--|
| | Rated (C of A) Capacity | 2022 Estimated Capacity | 2018 – 2022 Average Production | Remaining Capacity (Estimated Capacity – Average Production) | Infill Development Reserve Allocation (5% of Remaining Capacity) | Total Recommended Capacity (Includes allocated and requested Capacity) | Total Capacity Remaining after Infill Reserve and Recommended Allocation |
| Waste Water | | | | | | | |
| Caledonia | 7,200 | 7,200 | 3,140 | 4,060 | 203 | 2,236 | 1,621 |
| Cayuga | 1,200 | 1,200 | 806 | 394 | 20 | 235 | 139 |
| Dunnville | 7,728 | 7,728 | 4,560 | 3,168 | 158 | 789 | 2,221 |
| Hagersville | 4,200 | 4,200 | 2,310 | 1,890 | 95 | 1,082 | 713 |
| Jarvis Lagoon ³ | 853 | 1653 | 994 | 659 | 33 | 295 | 331 |
| Townsend Lagoon ³ | 2,095 | 1,295 | 272 | 1,023 | 51 | 163 | 809 |
| LEIP Lagoon | 657 | 657 | 702 | - | - | 0 | 0 |
| Water² | | | | | | | |
| Nanticoke | 13,600 | 13,600 | 10,308 | 3,292 | 165 | 1,172 | 1,956 |
| Dunnville ¹ | 14,500 | S*: 14,500 | 5,282 | 4,718 | 236 | 1,550 | 2,932 |
| | | W*:10,000 | | | | | |
| Caledonia/Cayuga (Hamilton Supply) | n/a | 13,800 | 4,991 | 8,809 | 440 | 6,054 | 2,067 |

Notes:

1. Colder water temperatures in winter months limit disinfection capability.
2. Water production values are based on maximum daily flow.
3. Estimated capacities for Jarvis and Townsend waste water reflect the Jarvis to Townsend connection.