

<i>* all units in m³/day</i>							
	Rated (C of A) Capacity	2023 Estimated Capacity	2019 – 2023 Average Production ³	Remaining Capacity (Estimated Capacity – Average Production)	Infill Development Reserve Allocation (5% of Remaining Capacity)	Total Recommended Capacity (Includes allocated and requested Capacity)	Total Capacity Remaining after Infill Reserve and Recommended Allocation
Waste Water							
Caledonia	7,200	7,200	3,204	3,996	200	2,067	1,729
Cayuga	1200	1200	814	386	19	149	218
Dunnville	7,728	7,728	4,607	3,121	156	634	2,331
Hagersville	4,200	4,200	2,210	1,990	100	1,082	807
Jarvis Lagoon	853	853	447 ¹	406	20	41	345
Townsend Lagoon	2,095	2,095	718 ¹	1,377	69	137	1,131
LEIP Lagoon	657	657	699	-	-	-	-
Water							
Nanticoke	13,600	13,600	10,603	2,997	150	993	1,854
Dunnville	14,500	S: 14,500	5,345	4,655	223	1,381	3,041
		W ² :10,000					
Caledonia/Cayuga (Hamilton Supply)	n/a	13,800	5,181	8,619	431	6,008	2,180

Notes:

1. Average production value represents operational flows from May 30 to Oct 4 2023 with new forcemain in service that connects Jarvis lagoons to Townsend lagoons.
2. Colder water temperatures in winter months limits disinfection capability.
3. Water production values are peak daily flow.